



Bushing Nameplate									
Designation	Serial #	Manufacturer	Type	C1 %PF	C1 Cap	C2 %PF	C2 Cap	Rated kV	Amps
H4	1503617125	ABB (ASEA-Brown Boveri)	O+C	0.4	281	0.7	500	69	1200

Bushing Test (C1)										
ID	Serial #	Test kV	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
H4	1503617125	10.002	1.049	0.0	1	0.261	0.38	278	281	Good

Bushing Test (C2)										
ID	Serial #	Test kV	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
H4	1503617125	0.50	1.93	0.1	1	0.473	0.7	512	500	Investigate