



Bushing Nameplate									
Designation	Serial #	Manufacturer	Type	C1 %PF	C1 Cap	C2 %PF	C2 Cap	Rated kV	Amps
H3	1S03617132	ABB (ASEA-Brown Boveri)	O+C	0.4	282	0.65	493	69	1200

Bushing Test (C1)										
ID	Serial #	Test kV	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
H3	1S03617132	10.003	1.054	0.0	1	0.259	0.36	279	282	Good

Bushing Test (C2)										
ID	Serial #	Test kV	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
H3	1S03617132	0.50	1.89	0.1	1	0.554	0.65	501	493	Good