



Bushing Nameplate									
Designation	Serial #	Manufacturer	Type	C1 %PF	C1 Cap	C2 %PF	C2 Cap	Rated kV	Amps
L1	1ZUA 1000060344	ABB (ASEA-Brown Boveri)	O+C II	0.3	406	0.3	4560	138	1600

Bushing Test (C1)										
ID	Serial #	Test kV	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
L1	1ZUA 1000060344	10.003	1.513	0.0	1	0.245	0.29	401	406	Good

Bushing Test (C2)										
ID	Serial #	Test kV	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
L1	1ZUA 1000060344	2.00	17.088	0.5	1	0.267	0.3	4533	4560	Good

