



| Bushing Nameplate | | | | | | | | | |
|-------------------|--------------------|----------------------------|--------|--------|--------|--------|--------|----------|------|
| Designation | Serial # | Manufacturer | Type | C1 %PF | C1 Cap | C2 %PF | C2 Cap | Rated kv | Amps |
| L2 | 1ZUA 1000061361 | ABB (ASEA-Brown Boveri) | O+C II | 0.3 | 404 | 0.28 | 4346 | 138 | 1600 |

| Bushing Test (C1) | | | | | | | | | | |
|-------------------|--------------------|---------|-------|-------|-----------|------------|--------|----------|--------|--------|
| ID | Serial # | Test kv | mA | Watts | Corr Fctr | PF*TCF [%] | NP %PF | Cap (pF) | NP Cap | FRANK™ |
| L2 | 1ZUA 1000061361 | 10.003 | 1.506 | 0.0 | 1 | 0.246 | 0.29 | 399 | 404 | Good |

| Bushing Test (C2) | | | | | | | | | | |
|-------------------|--------------------|---------|--------|-------|-----------|------------|--------|----------|--------|--------|
| ID | Serial # | Test kv | mA | Watts | Corr Fctr | PF*TCF [%] | NP %PF | Cap (pF) | NP Cap | FRANK™ |
| L2 | 1ZUA 1000061361 | 2.00 | 16.286 | 0.4 | 1 | 0.249 | 0.28 | 4320 | 4346 | Good |

