



Bushings Nameplate										
Designation	Serial #	Manufacturer	Type	C1 %PF	C1 Cap	C2 %PF	C2 Cap	Rated kV	Amps	
L3	1ZUA 1000061362	ABB (ASEA-Brown Boveri)	O+C II	0.3	402	0.28	4441	138	1600	

Bushings Test (C1)										
ID	Serial #	Test kV	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
L3	1ZUA 1000061362	10.003	1.497	0.0	1	0.247	0.28	397	402	Good

Bushings Test (C2)										
ID	Serial #	Test kV	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
L3	1ZUA 1000061362	2.00	16.653	0.5	1	0.278	0.28	4417	4441	Good

