



| Bushing Nameplate | | | | | | | | | |
|-------------------|------------|-------------------------|------|--------|--------|--------|--------|----------|------|
| Designation | Serial # | Manufacturer | Type | C1 %PF | C1 Cap | C2 %PF | C2 Cap | Rated kV | Amps |
| H2 | 3040690195 | ABB (ASEA-Brown Boveri) | O+C | 0.2 | 466 | * | * | 138 | 800 |

| Bushing Test (C1) | | | | | | | | | | |
|-------------------|------------|---------|-------|-------|-----------|------------|--------|----------|--------|--------|
| ID | Serial # | Test kV | mA | Watts | Corr Fctr | PF*TCF [%] | NP %PF | Cap (pF) | NP Cap | FRANK™ |
| H2 | 3040690195 | 10.003 | 1.727 | 0.0 | 1 | 0.22 | 0.2 | 458 | 466 | Good |

| Bushing Test (C2) | | | | | | | | | | |
|-------------------|------------|---------|-------|-------|-----------|------------|--------|----------|--------|--------|
| ID | Serial # | Test kV | mA | Watts | Corr Fctr | PF*TCF [%] | NP %PF | Cap (pF) | NP Cap | FRANK™ |
| H2 | 3040690195 | 2.00 | 2.753 | 0.2 | 1 | 0.682 | * | 730 | * | Good |

