



Bushing Nameplate									
Designation	Serial #	Manufacturer	Type	C1 %PF	C1 Cap	C2 %PF	C2 Cap	Rated kv	Amps
H0	3040690295	ABB (ASEA-Brown Boveri)	O+C	0.2	466	*	*	138	800

Bushing Test (C1)										
ID	Serial #	Test kv	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
H0	3040690295	10.003	1.731	0.1	1	0.314	0.2	459	466	Good

Bushing Test (C2)										
ID	Serial #	Test kv	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
H0	3040690295	2.00	2.79	0.2	1	0.632	*	740	*	Good

