



Bushing Nameplate									
Designation	Serial #	Manufacturer	Type	C1 %PF	C1 Cap	C2 %PF	C2 Cap	Rated kv	Amps
H3	3040690395	ABB (ASEA-Brown Boveri)	O+C	0.2	468	*	*	138	800

Bushing Test (C1)										
ID	Serial #	Test kv	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
H3	3040690395	10.003	1.731	0.0	1	0.222	0.2	459	468	Good

Bushing Test (C2)										
ID	Serial #	Test kv	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
H3	3040690395	2.00	2.803	0.2	1	0.601	*	743	*	Good

