



Bushing Nameplate									
Designation	Serial #	Manufacturer	Type	C1 %PF	C1 Cap	C2 %PF	C2 Cap	Rated kV	Amps
H0	3662800195	ABB (ASEA-Brown Boveri)	O+C	0.2	265	*	*	69	1200

Bushing Test (C1)										
ID	Serial #	Test kV	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
H0	3662800195	10.003	0.993	0.0	1	0.201	0.23	263	265	Good

Bushing Test (C2)										
ID	Serial #	Test kV	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
H0	3662800195	0.50	1.985	0.1	1	0.589	*	527	*	Good