



Bushing Nameplate									
Designation	Serial #	Manufacturer	Type	C1 %PF	C1 Cap	C2 %PF	C2 Cap	Rated kV	Amps
H1	3662800295	ABB (ASEA-Brown Boveri)	O+C	0.2	266	*	*	69	1200

Bushing Test (C1)										
ID	Serial #	Test kV	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
H1	3662800295	10.003	0.996	0.0	1	0.254	0.22	264	266	Good

Bushing Test (C2)										
ID	Serial #	Test kV	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
H1	3662800295	0.50	2.079	0.1	1	0.714	*	552	*	Good