



Bushing Nameplate									
Designation	Serial #	Manufacturer	Type	C1 %PF	C1 Cap	C2 %PF	C2 Cap	Rated kV	Amps
H2	3662800995	ABB (ASEA-Brown Boveri)	O+C	0.2	264	*	*	69	1200

Bushing Test (C1)										
ID	Serial #	Test kV	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
H2	3662800995	10.003	0.993	0.0	1	0.236	0.23	263	264	Good

Bushing Test (C2)										
ID	Serial #	Test kV	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
H2	3662800995	0.50	2.038	0.1	1	0.474	*	541	*	Good