



Bushing Nameplate									
Designation	Serial #	Manufacturer	Type	C1 %PF	C1 Cap	C2 %PF	C2 Cap	Rated kV	Amps
X3	3729120288	Westinghouse Electric	O+C	0.3	332	*	4001.5	138	800

Bushing Test (C1)										
ID	Serial #	Test kV	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
X3	3729120288	10.002	1.229	0.0	1	0.158	0.27	326	332	Good

Bushing Test (C2)										
ID	Serial #	Test kV	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
X3	3729120288	2.00	15.048	0.4	1	0.24	*	3992	4002	Good