



| Bushing Nameplate | | | | | | | | | |
|-------------------|------------|-----------------------|------|--------|--------|--------|--------|----------|------|
| Designation | Serial # | Manufacturer | Type | C1 %PF | C1 Cap | C2 %PF | C2 Cap | Rated kV | Amps |
| X2 | 3729120588 | Westinghouse Electric | O+C | 0.3 | 333 | * | 4007.7 | 138 | 800 |

| Bushing Test (C1) | | | | | | | | | | |
|-------------------|------------|---------|-------|-------|-----------|------------|--------|----------|--------|--------|
| ID | Serial # | Test kV | mA | Watts | Corr Fctr | PF*TCF [%] | NP %PF | Cap (pF) | NP Cap | FRANK™ |
| X2 | 3729120588 | 10.003 | 1.233 | 0.0 | 1 | 0.167 | 0.26 | 327 | 333 | Good |

| Bushing Test (C2) | | | | | | | | | | |
|-------------------|------------|---------|--------|-------|-----------|------------|--------|----------|--------|--------|
| ID | Serial # | Test kV | mA | Watts | Corr Fctr | PF*TCF [%] | NP %PF | Cap (pF) | NP Cap | FRANK™ |
| X2 | 3729120588 | 2.00 | 15.087 | 0.4 | 1 | 0.255 | * | 4002 | 4008 | Good |