



Bushing Nameplate									
Designation	Serial #	Manufacturer	Type	C1 %PF	C1 Cap	C2 %PF	C2 Cap	Rated kV	Amps
L0	3746160489	Westinghouse Electric	O+C	0.3	341	*	4173.6	138	800

Bushing Test (C1)										
ID	Serial #	Test kV	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
L0	3746160489	10.003	1.263	0.0	1	0.228	0.26	335	341	Good

Bushing Test (C2)										
ID	Serial #	Test kV	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
L0	3746160489	2.00	15.741	0.3	1	0.206	*	4176	4174	Good