



Bushing Nameplate									
Designation	Serial #	Manufacturer	Type	C1 %PF	C1 Cap	C2 %PF	C2 Cap	Rated kV	Amps
X4	3S05035011	ABB (ASEA-Brown Boveri)	O+C	0.3	354	0.29	4331	138	1600

Bushing Test (C1)										
ID	Serial #	Test kV	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
X4	3S05035011	10.003	1.318	0.0	1	0.27	0.27	350	354	Good

Bushing Test (C2)										
ID	Serial #	Test kV	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
X4	3S05035011	2.00	16.236	0.4	1	0.262	0.29	4307	4331	Good