



Bushings Nameplate									
Designation	Serial #	Manufacturer	Type	C1 %PF	C1 Cap	C2 %PF	C2 Cap	Rated kV	Amps
H6	7C00745509	ABB (ASEA-Brown Boveri)	O+C	0.2	359	*	3717	115	1200

Bushings Test (C1)										
ID	Serial #	Test kV	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
H6	7C00745509	10.002	1.341	0.0	1	0.36	0.24	356	359	Good

Bushings Test (C2)										
ID	Serial #	Test kV	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
H6	7C00745509	2.00	13.937	0.4	1	0.312	*	3697	3717	Good

