



Bushing Nameplate									
Designation	Serial #	Manufacturer	Type	C1 %PF	C1 Cap	C2 %PF	C2 Cap	Rated kv	Amps
Y2	7C00745510	ABB (ASEA-Brown Boveri)	O+C	0.2	357	*	3684	115	1600

Bushing Test (C1)										
ID	Serial #	Test kv	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
Y2	7C00745510	10.003	1.329	0.0	1	0.316	0.24	353	357	Good

Bushing Test (C2)										
ID	Serial #	Test kv	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
Y2	7C00745510	2.00	13.899	0.5	1	0.381	*	3687	3684	Good

