



Bushing Nameplate									
Designation	Serial #	Manufacturer	Type	C1 %PF	C1 Cap	C2 %PF	C2 Cap	Rated kv	Amps
H4	7C00832202	ABB (ASEA-Brown Boveri)	O+C	0.2	486	*	*	138	800

Bushing Test (C1)										
ID	Serial #	Test kv	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
H4	7C00832202	10.002	1.81	0.1	1	0.285	0.24	480	486	Good

Bushing Test (C2)										
ID	Serial #	Test kv	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
H4	7C00832202	2.00	2.814	0.2	1	0.653	*	747	*	Good

