



Bushing Nameplate									
Designation	Serial #	Manufacturer	Type	C1 %PF	C1 Cap	C2 %PF	C2 Cap	Rated kV	Amps
H1	7C00832203	ABB (ASEA-Brown Boveri)	O+C	0.2	484	*	*	138	800

Bushing Test (C1)										
ID	Serial #	Test kV	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
H1	7C00832203	10.003	1.802	0.1	1	0.3	0.24	478	484	Good

Bushing Test (C2)										
ID	Serial #	Test kV	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
H1	7C00832203	2.00	2.672	0.2	1	0.562	*	709	*	Good

