



Bushings Nameplate									
Designation	Serial #	Manufacturer	Type	C1 %PF	C1 Cap	C2 %PF	C2 Cap	Rated kv	Amps
L6	8S01037401	ABB (ASEA-Brown Boveri)	O+C	0.2	358	*	3756	115	1600

Bushings Test (C1)										
ID	Serial #	Test kv	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
L6	8S01037401	10.003	1.33	0.0	1	0.234	0.23	353	358	Good

Bushings Test (C2)										
ID	Serial #	Test kv	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
L6	8S01037401	2.00	14.153	0.5	1	0.387	*	3754	3756	Good

