



Bushing Nameplate									
Designation	Serial #	Manufacturer	Type	C1 %PF	C1 Cap	C2 %PF	C2 Cap	Rated kv	Amps
Y1	8S01037402	ABB (ASEA-Brown Boveri)	O+C	0.2	356	*	3784	115	1600

Bushing Test (C1)										
ID	Serial #	Test kv	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
Y1	8S01037402	10.002	1.327	0.0	1	0.225	0.22	352	356	Good

Bushing Test (C2)										
ID	Serial #	Test kv	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
Y1	8S01037402	2.00	14.226	0.4	1	0.293	*	3774	3784	Good

