



Bushing Nameplate									
Designation	Serial #	Manufacturer	Type	C1 %PF	C1 Cap	C2 %PF	C2 Cap	Rated kv	Amps
X0	8501124814	ABB (ASEA-Brown Boveri)	O+C	0.4	544	*	*	25	400

Bushing Test (C1)										
ID	Serial #	Test kv	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
X0	8501124814	10.003	2.068	0.1	1	0.47	0.4	549	544	Good

Bushing Test (C2)										
ID	Serial #	Test kv	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
X0	8501124814	0.50	1.701	0.1	1	0.466	*	451	*	Good

