



Bushing Nameplate									
Designation	Serial #	Manufacturer	Type	C1 %PF	C1 Cap	C2 %PF	C2 Cap	Rated kV	Amps
H5	8S01154528	ABB (ASEA-Brown Boveri)	O+C	0.3	275	*	*	69	1200

Bushing Test (C1)										
ID	Serial #	Test kV	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
H5	8S01154528	10.002	1.016	0.0	1	0.183	0.25	270	275	Good

Bushing Test (C2)										
ID	Serial #	Test kV	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
H5	8S01154528	0.50	1.952	0.1	1	0.517	*	518	*	Good