



Bushing Nameplate									
Designation	Serial #	Manufacturer	Type	C1 %PF	C1 Cap	C2 %PF	C2 Cap	Rated kV	Amps
L5	91-55100	Lapp	NONE	0.2	402	*	1779	115	1600

Bushing Test (C1)										
ID	Serial #	Test kV	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
L5	91-55100	10.002	1.513	0.0	1	0.29	0.24	401	402	Good

Bushing Test (C2)										
ID	Serial #	Test kV	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
L5	91-55100	2.00	6.782	0.2	1	0.36	*	1799	1779	Good