



Bushing Nameplate									
Designation	Serial #	Manufacturer	Type	C1 %PF	C1 Cap	C2 %PF	C2 Cap	Rated kv	Amps
X1	9501496310	ABB (ASEA-Brown Boveri)	O+C	0.4	547	*	*	25	1200

Bushing Test (C1)										
ID	Serial #	Test kv	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
X1	9501496310	10.003	2.069	0.1	1	0.453	0.35	549	547	Good

Bushing Test (C2)										
ID	Serial #	Test kv	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
X1	9501496310	0.50	1.571	0.1	1	0.532	*	417	*	Good

