



| Bushing Nameplate |          |                       |      |        |        |        |        |          |      |
|-------------------|----------|-----------------------|------|--------|--------|--------|--------|----------|------|
| Designation       | Serial # | Manufacturer          | Type | C1 %PF | C1 Cap | C2 %PF | C2 Cap | Rated kV | Amps |
| X5                | K7214086 | Westinghouse Electric | O+   | 0.3    | 433    | *      | 3270   | 115      | 1600 |

| Bushing Test (C1) |          |         |      |       |           |            |        |          |        |        |
|-------------------|----------|---------|------|-------|-----------|------------|--------|----------|--------|--------|
| ID                | Serial # | Test kV | mA   | Watts | Corr Fctr | PF*TCF [%] | NP %PF | Cap (pF) | NP Cap | FRANK™ |
| X5                | K7214086 | 10.002  | 1.58 | 0.0   | 1         | 0.266      | 0.31   | 419      | 433    | Good   |

| Bushing Test (C2) |          |         |        |       |           |            |        |          |        |        |
|-------------------|----------|---------|--------|-------|-----------|------------|--------|----------|--------|--------|
| ID                | Serial # | Test kV | mA     | Watts | Corr Fctr | PF*TCF [%] | NP %PF | Cap (pF) | NP Cap | FRANK™ |
| X5                | K7214086 | 2.00    | 12.046 | 0.3   | 1         | 0.234      | *      | 3195     | 3270   | Good   |