



Bushing Nameplate									
Designation	Serial #	Manufacturer	Type	C1 %PF	C1 Cap	C2 %PF	C2 Cap	Rated kV	Amps
H0X0	K7214486	Westinghouse Electric	O+	0.3	434	*	3179.9	115	1600

Bushing Test (C1)										
ID	Serial #	Test kV	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
H0X0	K7214486	10.003	1.582	0.0	1	0.26	0.3	420	434	Good

Bushing Test (C2)										
ID	Serial #	Test kV	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
H0X0	K7214486	2.00	11.716	0.3	1	0.227	*	3108	3180	Good