



Bushing Nameplate									
Designation	Serial #	Manufacturer	Type	C1 %PF	C1 Cap	C2 %PF	C2 Cap	Rated kV	Amps
X6	K7224386	Westinghouse Electric	O+	0.3	397	*	3199.1	115	1600

Bushing Test (C1)										
ID	Serial #	Test kV	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
X6	K7224386	10.002	1.539	0.0	1	0.184	0.26	408	397	Good

Bushing Test (C2)										
ID	Serial #	Test kV	mA	Watts	Corr Fctr	PF*TCF [%]	NP %PF	Cap (pF)	NP Cap	FRANK™
X6	K7224386	2.00	12.425	0.3	1	0.227	*	3296	3199	Good